



NOTE:
 STUBOUTS TO BE A MIN. OF 5' LONG AND SUPPORTED BY EMBEDMENT SPECIFIED IN PLANS.
 STUBOUTS TO BE GROUTED AT MANHOLE WITH NON-SHRINK GROUT. STUBOUTS SHALL ALSO
 BE FITTED WITH WATERTIGHT STOPPER OR CAP.

STANDARD MANHOLE **DROP MANHOLE**

07_SSCS_STD_MH_DETAIL.Dwg



CITY OF LUFKIN
 ENGINEERING DEPARTMENT
 P.O. BOX 190
 LUFKIN, TEXAS 75902-0190
 PHONE: (936) 633-0414

SANITARY SEWER STANDARDS

**STANDARD SANITARY
 MANHOLE DETAIL**

07
 10-13-03