



- NOTE:**
1. ALL CONCRETE SHALL BE CLASS "A" CONCRETE.
 2. REINFORCING BARS SHALL BE STANDARD GRADE STEEL, DEFORMED REINFORCING BARS OF A DIAMETER AND LENGTH AS SHOWN.
 3. CHAMFER ALL EXPOSED CORNERS 3/4" EXCEPT WHERE NOTED OTHERWISE.
 4. DIMENSIONS RELATING TO REINFORCING STEEL ARE TO CENTERS OF BARS.
 5. CENTER REINFORCING STEEL IN WALL, UNLESS NOTED OTHERWISE.
 6. FIELD CUT AND BEND BARS AS NECESSARY TO ACCOMMODATE STORM SEWER PIPE.

CURB INLET CROSS-SECTION - A

07_CURB_INLET_XS.Dwg



CITY OF LUFKIN
 ENGINEERING DEPARTMENT
 P.O. BOX 190
 LUFKIN, TEXAS 75902-0190
 PHONE: (936) 633-0414

STORM SEWER STANDARDS

CURB INLET CROSS SECTION - A

07
 10-13-03